

NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.**Supply & Installation of Standby Diesel Generating Set 1500 RPM 30KVA at NBP Hasrat Mohani Road Branch , Karachi.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 05 Nos. firms who submitted their tenders by due date & time i.e. 14/09/2009 at 10:00 Hours and were opened the same day publicly at 11:00 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under:

S.#.	Parameter	Required Specification	M/s.Adamjee Diesel Engg.	M/s. S.M Jaffer & Co.	M/s. Forte Pakistan	M/s. Orient Engg. System	M/s. Greave Pakistan
1	Standby Rating	30 KVA or Higher	33 KVA	34.5 KVA	33 KVA	33 KVA	33 KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Perkins UK	Yanmar (Japan) Himoina	Jhon Deere ONIS VISA	Jhon Deere ONIS VISA	Jhon Deere SDMO
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Stamford	Stamford	Stamford Itly	Stamford	MECC-ALTE
4	Warranty	01 Year	1 year	1 year	1 year	1 year	1 year
5	Bid Amount		Rs.1,125,000/-	Rs.1,099,070/-	Rs.985,750/-	Rs.1,022,600/-	Rs.1,125,000/-
6	Earnest Money Amount		Rs.29,066/-	Rs.40,000/-	Rs.20,000/-	Rs.23,000/-	Rs.36,000/-

The salient features and rates of all the bidders were announced then and there. The rates of M/s. Forte Pakistan Pvt. Ltd. for total tender amount of Rs.985,750/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

(Syed Humayoun Perwaiz)
AVP/Incharge Electrical Section