

BID EVALUATION REPORT
NATIONAL BANK OF PAKISTAN, ENGINEERING WING (CENTRAL) LAHORE
SUPPLY AND INSTALLATION OF 10 / 13 KVA 01 NO. D.G SET AT NBP RAIWIND BRANCH, (EAST REGION, LAHORE)

Sealed tenders were invited from reputed diesel generator sets supplying firms by publicizing advertisement on NBP & PPRA websites for supply & installation of 10 KVA diesel generator set with ATS panel and canopy at NBP Raiwind branch of East Region, Lahore as per PPRA rules. The tenders were received and opened on due date & time i.e 30-07-2012 at 1100 hours and were opened on same day publicly at 1130 hours in the presence of tender opening committee and contractors or their agents. Four contractors purchased tender documents and participated in tendering. The tenders have been checked by Engineering Department. Following is the technical & financial bids evaluation report.

			1	2	3	4.
Sr. No.	Description	Required specification	M/s. S.M Jaffer & Co.	M/s. Allied Engineering & Services (Pvt.) Ltd.	M/s. Synergy Corporation	M/s. Technovision (Pvt.) Ltd.
1.	PEC registration	Valid PEC registration C6 or above	Provided	Provided	Provided	Not provided
2.	Rating	10 KVA Prime	16.5 KVA	12.5 KVA	10.9 KVA	10 KVA
3.	Engine	U.K, USA, Japan or equivalent	Perkin (U.K) 404D-22 G1	Perkin (U.K) 403D-15G	Lister Peter (U.K) LLD 140 (A) LPW 3	HATZ CHV (France) 1D81Z
4.	Alternator	U.K, USA, Japan or equivalent and Siemens Pakistan only	Leroy Somer (France) LL1014 L	Leroy Somer (France) LL 1014H	Lister Peter (U.K) WTW15	SOGA FT2MBS (U.K)
5.	Coupler	U.K, USA, Japan or reputed equivalent and Siemens Pakistan only	F.G. Wilson (U.K) P18-4	Cat-Olympian GEP 13.5-4	Lister Peter (U.K) LPW (Series)	SDMO (France) DX10015TE
6.	RPM	1500 RPM	1500 RPM	1500 RPM	1500 RPM	3000 RPM
7.	Fuel consumption	-----	4.4 L/H at 100% load	3.6 L/H at 100% load	2.8 L/H at 100% load	2.4 L/H at 100% load
8.	Warranty	01 Year	01 Year	01 Year	02 Year	01 Year
9.	Bid amount					
	BOQ-I	----	BOQ-I Rs.1,005,000/-	BOQ-I Rs. 844,000/-	BOQ-I Rs.739,480/-	BOQ-I Rs.551,000/-
	BOQ-II	----	BOQ-II Rs. 274,200/-	BOQ-II Rs. 280,900/-	BOQ-II Rs.197,500/-	BOQ-II Rs.229,500/-
	Total	----	Rs.1,279,200/-	Rs.1,124,900/-	Rs.936,980/-	Rs.780,500/-
10.	Earnest money	----	Rs.28,000/-	Rs.25,000/-	Rs.19,000/-	Rs.16000/-
11.	Remarks	----	4 th Lowest	3 rd Lowest	2 nd Lowest NOTE: Accepted.	1 st Lowest . NOTE: Rejected due to deviation in approved technical data.

The salient features and rates of all the bidders were announced then and there. Although the rates quoted by M/s Technovision (Pvt.) Ltd. are lowest but **rejected** due to deviation in approved technical specifications & requirements. It is therefore the 2nd lowest bid of M/s. Synergy Corporation for total tender amount of Rs.936,980/- was found to be the **responsive bid** for supply, installation, testing and commissioning of 10 / 13 KVA D.G set with M.S canopy, ATS panel with MOR, power cables etc. The tender rates are reasonable and justified as per approved specifications and other terms & conditions approved by the Bank.

Engr. SUHAIL ANWAR
DY. CHIEF ENGINEER
ENGG: WING (CENTRAL)
NBP, RHQ BUILDING, LAHORE

Engr. FAYYAZ AHMED
AVP-HEAD OF ELECTRICAL
ENGG: WING (CENTRAL)
NBP, RHQ BUILDING, LAHORE