



NATIONAL BANK OF PAKISTAN

Engineering Wing (Central)
26-Mclagon Road, RHQ Building, Lahore
Ph:042-99211216, Fax:042-99211223

**SUPPLY & INSTALLATION OF RADIATOR
AND EXPANSION TANK FOR 630 KVA DIESEL
GENERATOR SET INSTALLED AT
NBP RHQ BUILDING, LAHORE**

SUMMARY

1. S/I of Radiator & Expansion Tank of
630 KVA Diesel Generator Set Rs. _____

TOTAL:- Rs. _____

Note:- Note:- Bid should be inclusive of all types of applicable Govt. taxes

(RUPEES _____)

M/S. _____

ADDRESS _____

Contact # (Office) _____

Contact # (Mobile) _____

E-mail: _____

FOR NATIONAL BANK OF PAKISTAN

CONTRACTOR

NATIONAL BANK OF PAKISTAN

BILL OF QUANTITIES

**SUPPLY & INSTALLATION OF RADIATOR AND EXPANSION TANK
FOR 630 KVA DIESEL GENERATOR SET INSTALLED
AT NBP RHQ BUILDING, LAHORE**

<u>Sr. No.</u>	<u>Description</u>	<u>Qty</u>	<u>Unit Rate</u> (Rs.)	<u>Amount</u> (Rs.)
01	Supply and installation of "Volvo" Genuine, Radiator, (Part No.: 3838130) for 630 KVA Volvo Diesel Generator (D.G Set Model No.: TAD1642GE), as approved by Engineer Incharge, complete with all accessories & connections in all respects.	01 Job		
02	Supply and installation of "Volvo" Genuine, Expansion Tank, (Part No.: 1674916) for 630 KVA Volvo Diesel Generator (D.G Set Model No.: TAD1642GE) as approved by Engineer Incharge, complete with all accessories & connections in all respects.	01 Job		
03	Supply and installation of "Volvo" Genuine, Fuel Filter Housing, (Part No.: 22035823) for 630 KVA Volvo Diesel Generator (D.G Set Model No.: TAD1642GE) as approved by Engineer Incharge, complete with all accessories & connections in all respects.	01 Job		
04	Testing and commissioning of 630 KVA Volvo Diesel Generator on load after replacement of spare parts for minimum three hours to observe any leakages as approved by Engineer Incharge.	01 Job		
			Total:	


For NATIONAL BANK OF PAKISTAN

CONTRACTOR

GENERAL TERMS & CONDITIONS

SUPPLY & INSTALLATION OF RADIATOR AND EXPANSION TANK FOR 630 KVA DIESEL GENERATOR SET INSTALLED AT NBP RHQ BUILDING, LAHORE

The contractor/vendor will ensure the quality of works in accordance with standard specification, BOQ to follow under noted parameters before commencement of works.

1. No additional & extra item of work should execute at sites prior approval from Engineer Incharge.
2. No deviation from standard specifications is allowed.
3. The contractor/vendor will be responsible for carrying out the works in true workmanship.
4. Always liaison with concern Engineer Incharge in execution of works and do not left over any BOQ item without discussion, justification & consent of Engineer Incharge.
5. During the execution of work, no wire, pipe, joint, clamp should be left loose.
6. The work of supply & installation of radiator and expansion tank of diesel generator set will be completed in specified time period. In case of delay a penalty of Rs.0.10% per day will be imposed by the Bank upto 10% of contract value and the Bank reserve the right to recover the penalty from contractor/vendor running bills.
7. The warranty of radiator, expansion tank and specific spare parts will be provided by the contractor/vendor. The contractor/vendor will also be responsible for replacement of defective parts like radiator, expansion tank, specific spare parts and any leakages from the radiator or expansion tank etc. during the warranty period.
8. No escalation in rates shall be paid by the Bank at any case.
9. The electric wiring should be provided in PVC / flexible conduit properly clamped.
10. All tools, electricity, welding plant etc. require for installation works will be arranged by the contractor/vendor.
11. No bill of the contractor/vendor will be paid without testing & commissioning of the diesel generator set on load and monitoring of the radiator and expansion tank's operation. The decision of the engineer Incharge will be final and binding.
12. The contractor / vendor should complete the work within three days positively from the date of award of work.
13. The contractor/vendor will be responsible to carry out the works beyond working hours / weekends.
14. The security measures will be managed by the contractor/vendor while execution of work, during beyond working hours / weekends.
15. The rates for supply & installation of radiator and expansion tank of diesel generator set should be inclusive all kind of taxes like sale tax, import duties / insurance etc.
16. The payment shall be made as per the actual works to be done at site.
17. Rates should be quoted on item rate basis as detail given in the BOQ.

Contd/...2



18. In case of any dispute arising during the execution of this contract the decision of the Department Head – Electrical / Wing Head (C) will be final and binding upon the Contract without appeal.
19. Poor quality work should not be accepted under any circumstances.
20. During execution of work contractor/vendor is responsible for the branch/office fixture, fittings, furniture and any damage to them is the responsibility of Contractor/vendor to be indemnified to Bank at actual cost.
21. The supplier may visit the site for examining scope of work and location before, quoting rates.
22. Any change in govt. taxes/duties and currency devaluation will be on supplier's account. Bank shall not entertain any claim what so ever.
23. No previous quotation reference will be considered and accepted.
24. The supplier will provide complete technical details, literature, original brochures along with tender.
25. No escalation in tender amount on any account what so ever shall be claimed by the supplier.
26. The running & final payment shall be released as per actual scope of work done and satisfactory supply.
27. 5% Security deposit/retention money will be retained from the bills which will be released after expiry of warranty period of one year from the date of completion of works.
28. A formal agreement shall be executed between the supplier and the Bank on approved performa.
29. Bank reserves the right to reject any tender or part thereof without assigning any reason.
30. The details of terms & conditions related to subject works, as given in tender documents should be strictly followed.


AVP/ HEAD OF ELECTRICAL

CONTRACTOR/VENDOR