

**NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.****Supply and Installation of 40KVA Standby Diesel Generator Set at NBP Awami Markaz Branch, Karachi.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 03 Nos. firms. However the firms submitted their tenders by due date & time i.e. 18/11/2009 at 10:00 Hours and were opened the same day publicly at 11:00 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under :

<b>S.#.</b>	<b>Parameter</b>	<b>Required Specification</b>	<b>M/s.S.M.Jaffar &amp; Co.</b>	<b>M/s. Adamjee Diesel Engg.</b>	<b>M/s. Synergy Corporation</b>
1	Standby Rating	40 KVA or Higher	44KVA	45 KVA	44KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Himoinsa yanmar Japan	Perkins UK	Lister Pitter
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Satmford	Leroy Somer AD Power	ABB UK
4	Warranty	01 Year	1 year	1 year	1 year
5	Bid Amount		Rs.1,068,500/-	Rs.1,166,750/-	Rs.1,137,500/-
6	Earnest Money Amount		Rs.40,000/-	Rs,24,770/-	Rs.23,000/-

The salient features and rates of all the bidders were announced then and there. The rates of M/s. S.M.Jaffar & Co..for total tender amount of Rs.1,068,500/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

( Syed Humayoun Perwaiz )  
**Asstt. Vice President /SRE (E)**

**NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.****Supply and Installation of 13KVA Standby Diesel Generator Set at NBP Rohri Branch, Sukkur Region.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 03 Nos. firms. However the firms submitted their tenders by due date & time i.e. 23/11/2009 at 10:00 Hours and were opened the same day publicly at 11:00 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under :

<b>S.#.</b>	<b>Parameter</b>	<b>Required Specification</b>	<b>M/s.S.M.Jaffar &amp; Co.</b>	<b>M/s. Adamjee Diesel Engg.</b>	<b>M/s. Synergy Corporation</b>
1	Standby Rating	13 KVA or Higher	13.8KVA	13.5 KVA	13KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Perkins UK	Perkins UK	Lister Pitter
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Leroy Somer F.G Wilson UK	Leroy Somer AD Power	ABB UK
4	Warranty	01 Year	1 year	1 year	1 year
5	Bid Amount		Rs.765,500/-	Rs.785,000/-	Rs.792,000/-
6	Earnest Money Amount		Rs.20,000/-	Rs,15,930/-	Rs.15,000/-

The salient features and rates of all the bidders were announced then and there. The rates of M/s. S.M.Jaffar & Co..for total tender amount of Rs.765,500/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

( Syed Humayoun Perwaiz )  
**Asstt. Vice President /SRE (E)**

**NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.****Supply and Installation of 13KVA Standby Diesel Generator Set at NBP Kashmore Branch, Larkana Region.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 03 Nos. firms. However the firms submitted their tenders by due date & time i.e. 18/11/2009 at 10:00 Hours and were opened the same day publicly at 12:00 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under :

<b>S.#.</b>	<b>Parameter</b>	<b>Required Specification</b>	<b>M/s.S.M.Jaffar &amp; Co.</b>	<b>M/s. Adamjee Diesel Engg.</b>	<b>M/s. Synergy Corporation</b>
1	Standby Rating	13 KVA or Higher	13.8KVA	13.5 KVA	13KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Perkins UK	Perkins UK	Lister Pitter
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Leroy Somer F.G Wilson UK	Leroy Somer AD Power	ABB UK
4	Warranty	01 Year	1 year	1 year	1 year
5	Bid Amount		Rs.777,100/-	Rs.785,000/-	Rs.792,000/-
6	Earnest Money Amount		Rs.20,000/-	Rs,15,930/-	Rs.15,000/-

The salient features and rates of all the bidders were announced then and there. The rates of M/s. S.M.Jaffar & Co..for total tender amount of Rs.777,100/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

( Syed Humayoun Perwaiz )  
**Asstt. Vice President /SRE (E)**

**NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.****Supply and Installation of 13KVA Standby Diesel Generator Set at NBP Sindh University Jamshoro Branch, Larkana Region.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 03 Nos. firms. However the firms submitted their tenders by due date & time i.e. 18/11/2009 at 10:00 Hours and were opened the same day publicly at 11:45 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under :

<b>S.#.</b>	<b>Parameter</b>	<b>Required Specification</b>	<b>M/s.S.M.Jaffar &amp; Co.</b>	<b>M/s. Adamjee Diesel Engg.</b>	<b>M/s. Synergy Corporation</b>
1	Standby Rating	13 KVA or Higher	13.8KVA	13.5 KVA	13KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Perkins UK	Perkins UK	Lister Pitter
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Leroy Somer F.G Wilson UK	Leroy Somer AD Power	ABB UK
4	Warranty	01 Year	1 year	1 year	1 year
5	Bid Amount		Rs.777,100/-	Rs.785,000/-	Rs.792,000/-
6	Earnest Money Amount		Rs.20,000/-	Rs,15,930/-	Nil

The salient features and rates of all the bidders were announced then and there. The rates of M/s. S.M.Jaffar & Co..for total tender amount of Rs.777,100/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

( Syed Humayoun Perwaiz )  
**Asstt. Vice President /SRE (E)**

**NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.****Supply and Installation of 13KVA Standby Diesel Generator Set at NBP L.M.C Jamshoro Branch, Larkana Region.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 03 Nos. firms. However the firms submitted their tenders by due date & time i.e. 18/11/2009 at 10:00 Hours and were opened the same day publicly at 11:30 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under :

S.#.	Parameter	Required Specification	M/s.S.M.Jaffar & Co.	M/s. Adamjee Diesel Engg.	M/s. Synergy Corporation
1	Standby Rating	13 KVA or Higher	13.8KVA	13.5 KVA	13KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Perkins UK	Perkins UK	Lister Pitter
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Leroy Somer F.G Wilson UK	Leroy Somer AD Power	ABB UK
4	Warranty	01 Year	1 year	1 year	1 year
5	Bid Amount		Rs.796,000/-	Rs.785,000/-	Rs.792,000/-
6	Earnest Money Amount		Rs.20,000/-	Rs,18,000/-	Rs.15,000/-/-

The salient features and rates of all the bidders were announced then and there. The rates of M/s .Adamjee Diesel Engg.for total tender amount of Rs.785,000/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

( Syed Humayoun Perwaiz )  
Asstt. Vice President /SRE (E)

**NATIONAL BANK OF PAKISTAN ENGINEERING WING OPERATION GROUP HEAD OFFICE KARACHI.****Supply and Installation of 13KVA Standby Diesel Generator Set at NBP Nasirabad Branch, Larkana Region.****Bid Evaluation Report**

Sealed tenders were invited from reputable firms through advertisement on NBP and PPRA Websites. In response tenders were obtained by 03 Nos. firms. However the firms submitted their tenders by due date & time i.e. 18/11/2009 at 10:00 Hours and were opened the same day publicly at 11:15 Hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under :

S.#.	Parameter	Required Specification	M/s.S.M.Jaffar & Co.	M/s. Adamjee Diesel Engg.	M/s. Synergy Corporation
1	Standby Rating	13 KVA or Higher	13.8KVA	13.5 KVA	13KVA
2	Engine	Cummins, Isuzu, Kabuta, Perkins or Equivalent	Perkins UK	Perkins UK	Lister Pitter
3	Alternator	Denyo, Leray Somer, Stamford or Equivalent	Leroy Somer F.G Wilson UK	Leroy Somer AD Power	ABB UK
4	Warranty	01 Year	1 year	1 year	1 year
5	Bid Amount		Rs.795,000/-	Rs.785,000/-	Rs.792,000/-
6	Earnest Money Amount		Rs.20,000/-	Rs,18,000/-	Rs.15,000/-/-

The salient features and rates of all the bidders were announced then and there. The rates of M/s .Adamjee Diesel Engg.for total tender amount of Rs.785,000/- was found to be the lowest responsive bid. The tender rates are reasonable, justified, as per specifications & prevailing market prices and other terms & conditions approved by the Bank

( Syed Humayoun Perwaiz )  
Asstt. Vice President /SRE (E)