

NATIONAL BANK OF PAKISTAN, LOGISTIC SUPPORT & ENGINEERING DIVISION CMG HEAD OFFICE, KARACHI**Supply & Installation of 30KVA Standby Diesel Generator set at NBP,
Binnori Town Branch, Karachi (West).****Bid Evaluation Report**

Sealed tenders were invited through NBP and PPRA Websites. In response tenders were obtained by 06 Nos firms, out of which 05 Nos. firms submitted their tenders by due date & time i.e. 21/11/2011 at 11:00 hours and were opened the same day publicly at 12:00 hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under:

S.#.	Parameter	Required Specification	M/s. S.M. Jaffar & Co. Pvt. Ltd.	M/s. Greave Pakistan Pvt. Ltd.	M/s. Siemens Pakistan	M/s. Synergy Corporation	M/s. Jaffer Brothers
1	Standby Rating	30 KVA	30 KVA	33KVA	38KVA	33KVA	33 KVA
2	Engine	Europe/USA/Japan make	Perkins, UK 1103-33G1	John Deere	Cummins 4B3.3G1	Lister	Perkins 1103A-33G
3	Alternator	Europe/USA/Japan make	Leroy Somer LL1014Q	Mecc-Alte	Siemens	Lister Petter	Mecc-Alte
4	Coupler	Europe/USA/Japan make	FG Wilson UK	SDMO- France	Siemens	Lister Petter	Green Power
5	Fuel Consumption	50% Load 100% Load	3.6 liters 6.2 liters	3.6 liters/hour 6.8 liters/hour	3.7 liters/hour 7.2 liters/hour	4.0 liters/hour 8.0 liters/hour	3.9 liters/hour 7.1 liters/hour
6	Bid Amount		Rs.1,317,500/-	Rs.1,379,069/-	Rs.1,764,200/-	Rs.1,298,300/-	Rs.1,405,250/-
7	Earnest Money Amount		Rs.30,000/-	Rs.34,000/-	Rs.42,000/-	Rs.26,000/-	Rs.36,000/-

The salient features and rates of all the bidders were announced then and there. The bid of M/s. **M/s. Synergy Corporation** amounting to Rs.1,298,300/- was found to be the **LOWEST RESPONSIVE BID**. The tender rates are reasonable, justified, as per requirement & prevailing market prices and other terms & conditions approved by the Bank.

(Syed Kamran Ahmed)
Asstt.Vice President/XEN (E)

NATIONAL BANK OF PAKISTAN, LOGISTIC SUPPORT & ENGINEERING DIVISION CMG HEAD OFFICE, KARACHI

**Supply & Installation of 20KVA Standby Diesel Generator set at NBP,
Clifton (Former NDFC) Branch, Karachi (South).**

Bid Evaluation Report

Sealed tenders were invited through NBP and PPRA Websites. In response tenders were obtained by 06 Nos firms, out of which 04 Nos. firms submitted their tenders by due date & time i.e. 21/11/2011 at 11:00 hours and were opened the same day publicly at 11:30 hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under:

S.#.	Parameter	Required Specification	M/s. S.M. Jaffar & Co. Pvt. Ltd.	M/s. Greave Pakistan Pvt. Ltd.	M/s. Siemens Pakistan	M/s. Synergy Corporation	M/s. Jaffer Brothers
1	Standby Rating	20 KVA	22 KVA	22KVA	21.6 KVA	22KVA	22 KVA
2	Engine	Europe/USA/Japan make	Perkins, UK 404D-22G	Mitsubishi T22K	Perkins 404D-22G	Lister	Perkins (UK) 404D-22G
3	Alternator	Europe/USA/Japan make	Leroy Somer LL1014N	Mecc-Alte	Siemens	Lister Petter	Mecc-Alte
4	Coupler	Europe/USA/Japan make	FG Wilson UK	SDMO- France	Siemens	Lister Petter	Green Power
5	Fuel Consumption	50% Load 100% Load	2.9 liters 5.3 liters	3.4 liters/hour 6.2 liters/hour	2.9 liters/hour 5.3 liters/hour	2.4 liters/hour 4.9 liters/hour	2.5 liters/hour 5.4 liters/hour
6	Bid Amount		Rs.1,157,500/-	Rs.1,218,039/-	Rs.1,646,050/-	Rs.1,085,500/-	Rs.1,219,800/-
7	Earnest Money Amount		Rs.27,000/-	Rs.32,000/-	Rs.41,000/-	Rs.22,000/-	Rs.32,000/-

The salient features and rates of all the bidders were announced then and there. The bid of M/s. **M/s. Synergy Corporation** amounting of Rs.1,085,500/- was found to be the **LOWEST RESPONSIVE BID**. The tender rates are reasonable, justified, as per requirement & prevailing market prices and other terms & conditions approved by the Bank.

(Syed Kamran Ahmed)
Asstt.Vice President/XEN (E)

NATIONAL BANK OF PAKISTAN, LOGISTIC SUPPORT & ENGINEERING DIVISION CMG HEAD OFFICE, KARACHI**Supply & Installation of 13 KVA Standby Diesel Generator set at NBP,
Municipal Corporation Branch, Hyderabad Region.****Bid Evaluation Report**

Sealed tenders were invited through NBP and PPRA Websites. In response tenders were obtained by 06 Nos firms, out of which 04 Nos. firms submitted their tenders by due date & time i.e. 18/11/2011 at 11:00 hours and were opened the same day publicly at 12:30 hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under:

S.#.	Parameter	Required Specification	M/s. S.M. Jaffar & Co. Pvt. Ltd.	M/s. Greave Pakistan Pvt. Ltd.	M/s. Siemens Pakistan	M/s. Synergy Corporation
1	Standby Rating	13 KVA	18 KVA	16KVA	14.2 KVA	14 KVA
2	Engine	Europe/USA/Japan make	Perkins, UK 404D-22G	Mitsubishi T16K	Perkins 403D-15G	Lister
3	Alternator	Europe/USA/Japan make	FG Wilson UK	Mecc-Alte	Mecc-Alte	Lister Petter
4	Coupler	Europe/USA/Japan make	FG Wilson UK	SDMO- France	Siemens	Lister Petter
5	Fuel Consumption	50% Load 100% Load	2.6 liters 4..4 liters	2.6 liters/hour 4.4 liters/hour	2.0 liters/hour 3.7 liters/hour	1.4 liters/hour 2.8 liters/hour
6	Bid Amount		Rs.1,042,500/-	Rs.984,288/-	Rs.1,433,900/-	Rs.864,200/-
7	Earnest Money Amount		Rs.25,000/-	Rs.26,000/-	Rs.40,000/-	Rs.18,000/-

The salient features and rates of all the bidders were announced then and there. The bid of M/s. **M/s. Synergy Corporation** amounting to Rs.864,200/- was found to be the **LOWEST RESPONSIVE BID**. The tender rates are reasonable, justified, as per requirement & prevailing market prices and other terms & conditions approved by the Bank.

(Syed Kamran Ahmed)
Asstt.Vice President/XEN (E)

NATIONAL BANK OF PAKISTAN, LOGISTIC SUPPORT & ENGINEERING DIVISION CMG HEAD OFFICE, KARACHI

**Supply & Installation of 13 KVA Standby Diesel Generator set at NBP,
Kashmir Road Branch, Karachi (West).****Bid Evaluation Report**

Sealed tenders were invited through NBP and PPRA Websites. In response tenders were obtained by 06 Nos firms, out of which 04 Nos. firms submitted their tenders by due date & time i.e. 18/11/2011 at 11:00 hours and were opened the same day publicly at 12:00 hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under:

S.#.	Parameter	Required Specification	M/s. S.M. Jaffar & Co. Pvt. Ltd.	M/s. Greave Pakistan Pvt. Ltd.	M/s. Siemens Pakistan	M/s. Synergy Corporation
1	Standby Rating	13 KVA	18 KVA	16KVA	14.2 KVA	14 KVA
2	Engine	Europe/USA/Japan make	Perkins, UK 404D-22G	Mitsubishi T16K	Perkins 403D-15G	Lister
3	Alternator	Europe/USA/Japan make	FG Wilson UK	Mecc-Alte	Mecc-Alte	Lister Petter
4	Coupler	Europe/USA/Japan make	FG Wilson UK	SDMO- France	Siemens	Lister Petter
5	Fuel Consumption	50% Load 100% Load	2.6 liters 4..4 liters	2.6 liters/hour 4.4 liters/hour	2.0 liters/hour 3.7 liters/hour	1.4 liters/hour 2.8 liters/hour
6	Bid Amount		Rs.1,042,500/-	Rs.984,288/-	Rs.1,406,900/-	Rs.864,200/-
7	Earnest Money Amount		Rs.25,000/-	Rs.26,000/-	Rs.40,000/-	Rs.22,600/-

The salient features and rates of all the bidders were announced then and there. The bid of M/s. **M/s. Synergy Corporation** amounting to Rs.864,200/- was found to be the **LOWEST RESPONSIVE BID**. The tender rates are reasonable, justified, as per requirement & prevailing market prices and other terms & conditions approved by the Bank.

(Syed Kamran Ahmed)
Asstt.Vice President/XEN (E)

NATIONAL BANK OF PAKISTAN, LOGISTIC SUPPORT & ENGINEERING DIVISION CMG HEAD OFFICE, KARACHI

**Supply & Installation of 13 KVA Standby Diesel Generator set at NBP,
S.P.I.T Landhi Branch, Karachi (West).**

Bid Evaluation Report

Sealed tenders were invited through NBP and PPRA Websites. In response tenders were obtained by 06 Nos firms, out of which 04 Nos. firms submitted their tenders by due date & time i.e. 18/11/2011 at 11:00 hours and were opened the same day publicly at 11:30 hours in the presence of tender opening committee & representatives of participating bidders. The details of tenders are as under:

S.#.	Parameter	Required Specification	M/s. S.M. Jaffar & Co. Pvt. Ltd.	M/s. Greave Pakistan Pvt. Ltd.	M/s. Siemens Pakistan	M/s. Synergy Corporation
1	Standby Rating	13 KVA	18 KVA	16KVA	14.2 KVA	14 KVA
2	Engine	Europe/USA/Japan make	Perkins, UK 404D-22G	Mitsubishi T16K	Perkins 403D-15G	Lister
3	Alternator	Europe/USA/Japan make	FG Wilson UK	Mecc-Alte	Mecc-Alte	Lister Petter
4	Coupler	Europe/USA/Japan make	FG Wilson UK	SDMO- France	Siemens	Lister Petter
5	Fuel Consumption	50% Load 100% Load	2.6 liters 4..4 liters	2.6 liters/hour 4.4 liters/hour	2.0 liters/hour 3.7 liters/hour	1.4 liters/hour 2.8 liters/hour
6	Bid Amount		Rs.1,042,500/-	Rs.984,288/-	Rs.1,406,900/-	Rs.864,200/-
7	Earnest Money Amount		Rs.25,000/-	Rs.26,000/-	Rs.40,000/-	Rs.22,500/-

The salient features and rates of all the bidders were announced then and there. The bid of M/s. **M/s. Synergy Corporation** amounting to Rs.864,200/- was found to be the **LOWEST RESPONSIVE BID**. The tender rates are reasonable, justified, as per requirement & prevailing market prices and other terms & conditions approved by the Bank.

(Syed Kamran Ahmed)
Asstt.Vice President/XEN (E)