

BID EVALUATION REPORT
NATIONAL BANK OF PAKISTAN, ENGINEERING WING (CENTRAL) LAHORE
SUPPLY AND INSTALLATION OF 20 KVA (PRIME) 01 NO. D.G SET AT NBP SHAHDARA BRANCH, (CENTRAL REGION, LAHORE)

Sealed tenders were invited from reputed diesel generator sets supplying firms by publicizing advertisement on NBP & PPRA websites for supply & installation of 20 KVA (Prime) diesel generator set with ATS panel and canopy at NBP Shahdara branch of Central Region, Lahore as per PPRA rules. The tenders were received and opened on due date & time i.e 30-07-2012 at 1100 hours and were opened on same day publicly at 1130 hours in the presence of tender opening committee and contractors or their agents. Four contractors purchased tender documents and participated in tendering. The tenders have been checked by Engineering Department. Following is the technical & financial bids evaluation report.

Sr. No.	Description	Required specification	1	2	3.
			M/s. S.M Jaffer & Co.	M/s. Allied Engineering & Services (Pvt.) Ltd.	M/s. Technovision (Pvt.) Ltd.
1.	PEC registration	Valid PEC Registration C-6 or above.	Provided	Provided	Not Provided
2.	Rating	20 KVA Prime	20 KVA Prime	20 KVA (Prime)	19.1 KVA (Prime)
3.	Engine	U.K, USA, Japan or equivalent	Perkin (U.K) 404D-22 G	Perkin (U.K) 404D-22 G	Kohler (USA) KDW2204
4.	Alternator	U.K, USA, Japan or equivalent and Siemens Pakistan only	Leroy Somer (France) LL1014 N	Leroy Somer (France) LL1014 N	Macc Alate (Italy) ECP28-1L/4
5.	Coupler	U.K, USA, Japan or reputed equivalent and Siemens Pakistan only	F.G. Wilson (U.K) P22-4	Cat-Olympian GEP 22-4 (U.K)	SDMO K21 (France)
6.	RPM	1500 RPM	1500 RPM	1500 RPM	1500 RPM
7.	Fuel consumption	---	5.3 L/ H at 100% load	5.3 L/ H at 100% load	6.15 L/ H at 100% load
8.	Warranty	01 Year	01 Year	01 Year	01 Year
9.	Bid amount				
	BOQ-I	----	BOQ-I Rs.1,105,000/-	BOQ-I Rs.1,079,000/-	BOQ-I Rs. 986,000/-
	BOQ-II	----	<u>BOQ-II Rs. 274,200/-</u>	<u>BOQ-II Rs. 276,150/-</u>	<u>BOQ-II Rs. 237,925/-</u>
	Total	----	Rs.1,379,200/-	Rs.1,355,150/-	Rs.1,223,925/-
10.	Earnest money	----	Rs.30,000/-	Rs.28,000/-	Rs.27000/-
11.	Remarks	----	3 rd Lowest	2 nd Lowest NOTE: Accepted.	1 st . Lowest . NOTE: Rejected due to deviation in approved technical data.

The salient features and rates of all the bidders were announced then and there. Although the rates quoted by M/s Technovision (Pvt.) Ltd. are lowest but **rejected** due to deviation in approved technical specifications & requirements. It is therefore the 2nd lowest bid of M/s. Allied Engineering & Services (Pvt.) Ltd. for total tender amount of Rs.1,355,150/- was found to be the responsive bid for supply, installation, testing and commissioning of 20 KVA (Prime) D.G set with M.S canopy, ATS panel with MOR, power cables etc. The tender rates are reasonable & justified as per approved specifications and other terms & conditions approved by the Bank.

Engr. SUHAIL ANWAR
DY. CHIEF ENGINEER
ENGG: WING (CENTRAL)
NBP, RHQ BUILDING, LAHORE

Engr. FAYYAZ AHMED
AVP-HEAD OF ELECTRICAL
ENGG: WING (CENTRAL)
NBP, RHQ BUILDING, LAHORE