## BID EVALUATION REPORT NATIONAL BANK OF PAKISTAN, ENGINEERING WING (CENTRAL) LAHORE SUPPLY AND INSTALLATION OF 20 KVA D.G SETS AT 08 NOS. NBP BRANCHES OF REGIONAL OFFICE, MULTAN

Sealed tenders were invited from reputed generator sets supplying firms through press and NBP & PPRA websites for supply & installation of 20 KVA Prime diesel generator sets with ATS panels, canopies and power cabling etc. at 08 Nos. NBP branches of Regional Office, Multan as per PPRA rules. The tenders were received and opened on due date & time i.e 18-10-2011 at 1100 hours and were opened on same day publicly at 1130 hours in the presence of tender opening committee and contractors or their agents. Seven contractors purchased tender documents and four contractors participated in tendering. The tenders have been checked by Engineering Department. Following is the comparative statement of bids.

Sr.	Description	Required specification	M/s. Energy Solution (Pvt.)	M/s. S.M Jaffer & Co.	M/s. Allied Engineering &	M/s. Greaves Pakistan (Pvt.) Ltd.
No.			Ltd.		Services (Pvt.) Ltd.	
1.	Rating	20 KVA Prime	20 KVA Prime	20 KVA Prime	20 KVA Prime	20 KVA Prime
2.	Engine	European, USA, Japan or	Perkin U.K	Perkin U.K	Perkin U.K	Mitsubishi (Japan)
		equivalent	404D-22G	404D-22G	404D-22G	S4Q2.SD
3.	Alternator	European, USA, Japan or	Newage Stamford (U.K)	Leroy Somer (France)	Olympian	Meccalte (Italy)
		equivalent and Siemens	. ,	LL1014N	(Leroy Somer France)	ECO281L/4
		Pakistan only			LL1014N	
4.	Coupler	European, USA, Japan or	AKSA (Turkey)	F.G Wilson (U.K)	Cater Pillar	SDMO (France)
		reputed equivalent and	APD22P	P22-4	(Olympian) (U.K)	T22K
		Siemens Pakistan only			GEP22-4	
4.	Warranty	01 Year	01 Year	01 Year	01 Year	01 Year
5.	Bid amount					
	BOQ-I		Rs.68,67,200/-	Rs.74,12,000/-	Rs. 77,02,000/-	Rs.70,40,000/-
	BOQ-II		Rs.29,82,000/-	Rs.23,96,000/-	Rs. 22,98,000/-	Rs.29,12,000/-
	Total		Rs.98,49,200/-	Rs.98,08,000/-	Rs.1,00,00,000/-	Rs.99,52,000/-
6.	Earnest		Rs.610,000/- MCB	Rs.200,000/- Soneri Bank	Rs.200,000/- Soneri Bank	Rs.203,040/- NBP
	money		Combined CDR for four			
	_		tenders of total value			
			Rs.2,42,36,280/-			
7.	Remarks		2 <sup>ND</sup>	Successful bid	4 <sup>TH</sup>	3 <sup>RD</sup>

The salient features and rates of all the bidders were announced then and there. The rates of M/s. S.M Jaffer & Co. for total tender amount of Rs.98,08,000/- is found to be the lowest responsive bid for supply, installation, testing and commissioning of 08 Nos. 20 KVA (Prime) D.G sets with M.S canopies, ATS panels with MOR, power cables etc. The tender rates are reasonable, justified as per specifications and prevailing market prices and other terms & conditions approved by the Bank.

Engr. SUHAIL ANWAR DY. CHIEF ENGINEER (Central)

Engr. FAYYAZ AHMED HEAD OF ELECTRICAL