

BID EVALUATION REPORT
NATIONAL BANK OF PAKISTAN, ENGINEERING WING (CENTRAL) LAHORE
SUPPLY AND INSTALLATION OF 100 KVA D.G SET AT NBP CORPORATE BRANCH & OFFICE, MULTAN

Sealed tenders were invited from reputed generator sets supplying firms through press and NBP & PPRA websites for supply & installation of 100 KVA (Prime) diesel generator set with ATS panel, canopy and power cabling etc. at NBP Corporate branch & Office, Multan as per PPRA rules. The tenders were received and opened on due date & time i.e 18-10-2011 at 1100 hours and were opened on same day publicly at 1130 hours in the presence of tender opening committee and contractors or their agents. Six contractors purchased tender documents and five contractors participated in tendering. The tenders have been checked by Engineering Department. Following is the comparative statement of bids.

Sr. No.	Description	Required specification	M/s. Energy Solutions (Pvt.) Ltd.	M/s. S.M Jaffer & Co.	M/s. Allied Engineering & Services (Pvt.) Ltd.	M/s. Greaves Pakistan (Pvt.) Ltd.	M/s. Orient Energy System (Pvt.) Ltd.
1.	Rating	100 KVA Prime	100 KVA Prime	100 KVA Prime	100 KVA Prime	100 KVA Prime	100 KVA Prime
2.	Engine	European, USA, Japan or equivalent	Cummins U.K 6BTA5.9G5	Perkin (U.K) 1104C-44TAG2	Perkin (U.K) 1104C-44TAG2	John Deere 4045HF120	Cummins (U.K) 41SBEG1
3.	Alternator	European, USA, Japan or equivalent and Siemens Pakistan only	Newage Stamford (U.K) UC127401	Leroy Somer (France) LL3014B	Leroy Somer (France) LL3014B	Leroy Somer (France) LSA442VS45	Stamford (U.K) UC274C
4.	Coupler	European, USA, Japan or reputed equivalent and Siemens Pakistan only	AKSA (Turkey) AC110	F.G Wilson (U.K) P110-2	Cater Pillar (Olympian) (U.K) GEP 110-4	SDMO (France) J110K	Cummins (U.K) C110D5
4.	Warranty	01 Year	01 Year	01 Year	01 Year	01 Year	01 Year
5.	Bid amount						
	BOQ-I	----	Rs.15,89,200/-	Rs.18,15,000/-	Rs.17,70,700/-	Rs.17,85,000/-	Rs.19,90,000/-
	BOQ-II	----	Rs. 7,20,800/-	Rs. 5,92,250/-	Rs. 5,59,300/-	Rs. 6,41,500/-	Rs. 8,10,000/-
	Total	----	Rs.23,10,000/-	Rs.24,07,250/-	Rs.23,30,000/-	Rs.24,26,500/-	Rs.28,00,000/-
6.	Earnest money	----	Rs.610,000/- MCB Combined CDR for four tenders of total value Rs.2,42,36,280/-	Rs.150,000/- Soneri Bank	Rs.46,600/- Soneri Bank	Rs.48,530/- NBP	Rs.65,000/- HBL
7.	Remarks		Successful bid	3RD	2ND	4TH	5TH

The salient features and rates of all the bidders were announced then and there. The rates of M/s. Energy Solution (Pvt.) Ltd. for total tender amount of Rs.23,10,000/- is found to be the lowest responsive bid for supply, installation, testing and commissioning of 01 No. 100 KVA (Prime) D.G set with M.S canopy, ATS panel with MOR, power cables etc. The tender rates are reasonable, justified as per specifications and prevailing market prices and other terms & conditions approved by the Bank.

Engr. SUHAIL ANWAR
 DY. CHIEF ENGINEER (Central)

Engr. FAYYAZ AHMED
 HEAD OF ELECTRICAL