


## ADDENDUM

### Supply, Installation, testing and Commissioning of brand new 1500 KVA (Prime Rating) Diesel Generator Set synchronized with Gas Generator Sets installed at NBP Head Office Building Karachi.

(NBP Tender NO: NT-01/31/2023-1 & PPRA Tender ID No TS502071E; dated 31<sup>st</sup> Jan, 2023)

The following changes / clarifications / amendments are as follows: -

1. The Warranty sticker on equipment is required from Supplier / OEM.
2. USD / PKR parity inflation is not allowed. The currency of payment is Pak Rupees.
3. The prices will be based on duties and taxes applicable at the date of quotation / proposal. No change will be passed on to the buyer at any time. A Bid submitted with adjustable price will be treated as non-responsive and shall be rejected.
4. Genset origin from China is allowed.
5. Amount of performance guarantee is 5 % with taxes and duties. Duration is 01 year and will commence from the day of commissioning of equipment.
6. No advance payment is allowed.
7. Partial delivery and payment is allowed.
8. In case of failure to meet any of the deadlines given in completion time schedule, penalty of Rs. 2000/- per day shall be levied / recovered from contractor's bills to a maximum of 10 % of contract value.
9. SLD module operation philosophy, panel drawings and synchronizing (Dief Drawing) is vendor job.
10. Transformer is not required to be energized.
11. Power cable required are PVC/PVC.
12. Exhaust ventilation system measurement required i.e. length of exhaust pipe is job of vendor.
13. Air intake system is job of vendor.
14. Fuel tank capacity required of 24 hours running of genset.
15. Consumable spares are required for 500 Hours.

  
(Haider Ali Isani)  
Divisional Head

